

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1663

Dated: 11/09/2026

It is certified that an inspection team headed by SHASHIKANT MOHOD (C.S.I.)
(Name of Officers with designation) from MUNICIPAL COUNCIL RAISEN PHED
inspected the ST. FRANCIS CONVENT HR. SEC. SCHOOL RAISEN M.P.
(Name & Address of the school) on 11/9/2026 (date of inspection) and on the
basis of Water Test Report (Attached) bearing no. 235
dated 10/09/2026 of District Water Testing Lab (PHED Lab) certified that
the ST. FRANCIS CONVENT HR. SEC. SCHOOL (Name of school) has safe
drinking water facilities for the students and members of staff of the institution.
School also maintains the hygienic sanitation condition in the school building & the
campus as per norms prescribed by the Central/ State/ U.T. Govt.
This certificate is valid till ONE YEAR

Signature with Seal: Shashikant Mohod

Name : S. V. R. S. H. A. J. A. V.

Designation: C.M.O.

Name & Address of the Office

/Department: MUNICIPAL COUNCIL RAISEN

ST. FRANCIS CONVENT

HR. SEC. SCHOOL RAISEN M.P.

(Name & Address of the Institution)

Manager
St. Francis Convent Hr. Sec. School
Raisein (M.P.)

Principal
St. Francis Convent
Hr. Sec. School
Raisein (M.P.)

Note: This certificate is to be issued by authorized officer / PHED Lab / local bodies

District Water Testing Laboratory

Public Health Engineering Department

Dhaniyakhedi Road, Rahul Nagar, Raisen

Email-eeprai@nic.in Phone-07482-222095

Issue No: 235

DWTL/PHED/RAISEN

Date: 10.09.2026

ANALYSIS REPORT

Type of Sample :- Water Sample

Customer Name :- St Francis Convent H.S. School, Raisen

Particular of Sample :- Not Collected by PHED

Sample No.	District	Block	Village	Sample Qty	Sample Packing	Location	Source
1	Raisen			1ltr	ok	Tubewell, St Francis convent H.S. school	Water sample

Date of Receipt:-08.09.2026

Time of Receipt :- 11:00

Date of Analysis Started :- 08.09.2026

Date of Analysis Completed :- 09.09.2026

NATURE OF STUDY – CHEMICAL ANALYSIS

No	Characteristics	Test Method		Unit	AS Per BIS - 10500:2012 & Amendment sep.2018 for Drinking water		Results		
					Requirement (Desirable limit)	Permissible limit in the absence of Alternate source			
1	Total Hardness as CaCO_3	IS 3025 RA 2019	Part 21	mg/l	200	600	400		
2	Calcium as Ca	IS 3025 RA 2019	Part 40	mg/l	75	200	83.2		
3	Magnesium as Mg	IS 3025 RA 2019	Part 46	mg/l	30	100	24.62		
4	pH	IS 3025 RA 2019	Part 11	pH Scale	6.5 to 8.5	6.5 to 8.5	7.88		
5	Turbidity	IS 3025 RA 2019	Part 10	NTU	1.0	5.0	4.2		
6	Total Alkalinity as CaCO_3	IS 3025 RA 2019	Part 23	mg/l	200	600	320		
7	Chloride as Cl	IS 3025 RA 2019	Part 32	mg/l	250	1000	156		
8	TDS	By Meter		mg/l	500	2000	497.2		

Note: - 1. This report should not be produced partly or full without approval of signatory authority for legal purposes.

2. This recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible limit in the absence of alternate source" above which the source will have to be rejected.


3. The results refer only to tested samples and parameters tested.

4. Sample will be stored for a period of 5 days from the date of issue of report.

5. This Lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.


Principal
Francis Convent
Hr. Sec. School
Raisen (M.P.)


Manager
1 of 2
St. Francis Convent Hr. Sec. School
Raisen (M.P.)


Signatory Authority
CHEMIST,
P.H. Laboratory
RAISEN (M.P.)

District Water Testing Laboratory

Public Health Engineering Department
Dhaniyakhedi Road, Rahul Nagar, Raisen
Email-eeprai@nic.in Phone-07482-222095

Issue No 235

DWTL/PHED/RAISEN

Date: 10.09.2026

ANALYSIS REPORT

Type of Sample :- Water Sample

Customer Name :- St. Francis Convent H.S. School

Particular of Sample :- Not Collected by PHED

Sample No.	District	block	Village	Sample Qty	Sample Packing	Location	Source
1	Raisen			1ltr	ok	Tubewell, St francis convent H.S. school	Water sample

Date of Receipt :- 08.09.2026

Date of Analysis Started :- 08.09.2026

Time of Receipt :- 11:00

Date of Analysis Completed :- 09.09.2026


NATURE OF STUDY - CHEMICAL ANALYSIS

No	Characteristics	Test Method	Unit	AS Per BIS - 10500:2012 & Amendment sep.2018 for Drinking water		Results		
				Requirement (Desirable limit)	Permissible limit in the absence of Alternate source	1		
9.	Fluoride as F	IS 3025 RA 2013	Part 60	mg/l	1.0	1.5	0.32	
10.	Nitrate as NO ₃	IS 3025 RA 2019	Part 34	mg/l	45	45	2	
11.	Iron as Fe	IS 3025 RA 2014	Part 53	mg/l	1.0	1.0	0.16	
12.	Manganese as Mn	By Kit		mg/l	0.1	0.3	0.0	
13.	Conductivity	IS 3025 RA 2019	Part 14	µS/cm			1006	
14.	Arsenic	By Kit		mg/l	0.01	0.01	Nil	
15.	Faecal Coliform (TTC)	APHA 22 nd Edition	9211B	Per 100 ml	NIL	NIL	Nil	

- Note: - 1. This report should not be produced partly of full without approval of signatory authority for legal purposes.
2. This recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible limit in the absence of alternate source" above which the source will have to be rejected.
3. The results refer only to tested samples and parameters tested.
4. Sample will be stored for a period of 5 days from the date of issue of report.
5. This Lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.


Principal
St. Francis Convent
Hr. Sec. School
Raisen (M.P.)


Page 2 of 2
Manager
St. Francis Convent Hr. Sec. School
Raisen (M.P.)


Signatory Authority
CHEMIST,
L.D. Laboratory,
RAISEN (M.P.)